

CHECK YOUR RADIATORS

Please check your rooms for items that may fall or come into contact with the radiator pipe, and secure away in a safe location.



Residents reported the smell of burning plastic in their room. It was found that a phone charger had fallen behind a resident's bed (between the bed and wall) and landed on the radiator pipe. The phone charging cable/cord had been resting on the radiator pipe and began melting, and the smell of burnt plastic was noticed. Thankfully nothing started on fire.